



RECEIVED
2016 AUG 15 PM 2:41
BAY AREA AIR QUALITY
MANAGEMENT DISTRICT

NRG Energy Center San Francisco, LLC
14 Mint Plaza, Suite 200
San Francisco, CA. 94103-1835

August 3, 2016

Director of Compliance and Enforcement
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109
Attn: Title V Reports

Dear Sir/Madam,

Attached is the Title V Monitoring Report from the NRG Energy Center San Francisco, LLC. This report covers the period from February 1, 2016 to July 31, 2016. During this period, we have maintained continuous compliance with all requirements.

Sincerely,



Ted Vincent
Plant Manager
NRG Energy Center San Francisco
14 Mint Plaza, Suite 200, San Francisco, CA 94103
Office: 415.777.3415
Direct: 415.644.9784

August 3, 2016
Facility # B6151

Director of Compliance and Enforcement
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109
Attn: Title V Reports

Subject: Title V Semi-Annual Monitoring Report for the period February 1, 2016 to July 31, 2016.

The NRG Energy Center San Francisco herewith submits the Semi-Annual Report for Facility B6151. This report includes detailed reports and compliance reporting for the following sources for the Semi-Annual period February 1, 2016 to July 31, 2016:

S-3: Boiler 3
Status: Full Compliance

S-4: Boiler 4
Status: Full Compliance

S-5: Boiler 5
Status: Full Compliance

S-6: Boiler 6
Status: Full Compliance

S-7: Boiler 7
Status: Full Compliance

S-9: Boiler 8
Status: Full Compliance

S10: UST Tank #3
Status: Full Compliance (exempt source)

S-11: UST Tank #4
Status: Full Compliance (exempt source)

S-12: UST Tank #5
Status: Full Compliance (exempt source)

S-13: Emergency Standby Diesel Engine
Status: Full Compliance

Compliance Certification

Based on information and belief formed after reasonable inquiry, the statements and information in this report and the attached Compliance Certification Report form are true, accurate, and complete.

Sincerely,

A handwritten signature in black ink, appearing to read "Ted Vincent", with a stylized flourish at the end.

Ted Vincent
Plant Manager
Facility #B6151

Fuel Usage by Boiler

| Boiler / Source | Natural Gas (therms) | Diesel Oil (gal) | Comments |
|-----------------|-------------------------|---------------------|----------|
| Boiler 3 / S3 | 972,202 | 210 | |
| Boiler 4 / S4 | 275,288 | 451 | |
| Boiler 5 / S5 | 60,293 | 0 | |
| Boiler 6 / S6 | 60,834 | 0 | |
| Boiler 7 / S7 | 3,393,625 | 0 | |
| Boiler 8 / S9 | 548,278 | 0 | |
| Total | 6,553,690 | 661 | |

Note: Heat content Natural gas Fuel is 1013 BTU/scf based on PG&E records.
There was no oil operation during this reporting period.

Emergency Standby Generator Log (S-13)

[illegible]